

CLASSIFICATION OF PROPERTIES

MLTB-3646-2020- chapter I



for control tests (FPC) consistent with the norm PN-EN 14351-1+A2:2016 (outside the scope of accreditation)

Company: **DOMEL Sp. z o.o.**
ul. Akademicka 4, 18-400 Łomża

Product: double leaf window; main profiles: PVC
System:
Veka SL 82 MD
Trade name:
VECTOR

Test results are included in the following test reports registered under the number of the request MLTB-3646-2020




Test methods:

Air permeability
PN-EN 1026

Waterproofness
PN-EN 1027

Wind load resistance
PN-EN 12211

Security equipment capacity
PN-EN 14609

Classification standards	PN-EN 12207	PN-EN 12208	PN-EN 12210	Threshold value
Product type (B x H mm)  1500 x 1500	4	E900	C5	350 N
Notes: enveloped hardware Winkhaus activPilot.				

Mobilne Laboratorium Techniki Budowlanej Sp. z o. o.
head of laboratory *Mściuchowski Adam*

24-06-2020, Łomża

Term of control test within the FPC (ZKP): 24-06-2021

Initial Type Testing (ITT) remain valid until, if there is not change in the construction of window and external pedestrian doorset, the raw material or supplier of the components, or the production proces, which would affect significantly one or more of the characteristics. Consistently with PN-EN 14351-1+A2:2016 point 7.5 Continuous surveillance, assessment and approval of FPC, the producer should carry out FCP assessment together with current and quality control inspections of a product at least once a year. The inspections conducted in accordance with the inspection plan should confirm that the manufactured products have the same properties as the products subject to ITT.

Mobilne Laboratorium Techniki Budowlanej Sp. z o.o.
58-300 Wałbrzych, ul. Jana Kasprowicza 21 lok. 2
tel.: +48 74 840 14 63, www.badaniaokien.pl
biuro@badaniaokien.pl

Jednostka notyfikowana
(Notified body) NB 2189

